



**FIRE-RESISTANT EXTERNAL SECURITY STEEL DOOR**  
**FQ EI<sub>2</sub>60, RESISTANCE CLASS 3, OUTWARD OPENING**

ver01

**Recommended use**

External security door used between fire stop sections in industrial buildings, dwellings and office buildings, where fire resistance class of the door must be EI<sub>2</sub>60 and security class 3.

**Dimensions**

Fire resistance class maximum dimensions of the door frame are 1264 x 2260 mm or 1100 x 2595 mm. Burglar resistance class maximum dimensions of the door frame are 1308 x 2628 mm.

**Certificate of conformity**

Fire-resistance has been tested in testing laboratory of TÜV Eesti OÜ in Tallinn according to standard EN 1634-1:2008 and certified by Inspecta Estonia OU in accordance with the standard EN 16034:2014 and fire-resistance class EI<sub>2</sub>60.

Burglar resistance has been tested in testing laboratory of RISE (The research institute of Sweden) and certified by SBSC in accordance with the standard EN 1627:2021. Burglar resistance class 3 is from the opening side.

**Properties**

Resistance to repeated opening and closing, EN 1191, class*	C5; 200000 cycles
Smoketightness, EN 1634-3, class*	S <sub>a</sub> / S <sub>200</sub>
Sound insulation: Rw; EN ISO 717-1	40 dB
Watertightness, EN 1027, class*	3A
Air permeability, EN 1026, class*	4
Resistance to wind load, EN 12211, class** *	C4
Thermal transmittance, EN 10077*	1,6 W/(m <sup>2</sup> K)

\*Declared values depend on the size of the door.

\*\*Up to frame width 1120 mm.

**Construction**

**Door leaf** is 64 mm thick. Rebates are at the sides and at the top. External side is made of 1,5 mm and internal side of 1,0 mm hot-dip galvanized steel sheets connected with rivets. Insulation material is fire-resistant mineral wool. Rigidity of the door leaf is achieved with security elements and via gluing together the metal and the insulation material. There are 2 hinges with ball bearings. Door leaf is secured with 3 security pins.

**Frame** is made of hot-dip galvanized steel sheet profiles with a thickness of 1,5 mm, connected at the corners with screws and rivets. Insulation material is fire-resistant mineral wool. Frame can be ordered with cover slat covering lateral installation slots (type YM) or without cover slat for installation deeper than wall surface (type YS). Seal is made of silicone rubber and is fitted into the groove of the frame.

**Threshold** is made of hot-dip galvanized steel sheet.

**Finish**

Door is coated with polyester powder coating. Standard tones are RAL7001 (silver gray), RAL7024 (graphite grey), RAL8014 (sepia brown), RAL9006 (white aluminum) and RAL9010 (pure white). Alternatively the door can be painted with epoxy primer and two component polyurethane paint in all the tones of RAL catalogue.

**Locks**

SBSC approved main-locks need to be used. For example Assa 410 with 1490-11. Permitted to use fire-resistant additional locks by Assa, Abloy etc. For more information contact our sales team.

**Installation**

Frame is fixed from seven points with steel sleeves and screws. Fixing apertures are covered with plastic plugs. Installation gap will be filled with mineral wool or construction foam after fixing. Package includes fixings and plugs. For more details see installation manual.

**Accessories**

Stainless steel threshold, gradient threshold, border slats, peephole, security chain, foot sheet, lock case, core, core covers, door handle. Door closer with non-detachable arm must be installed to the door located in evacuation path. Door closer Abloy DC335BC can be used.

**Maintenance**

Door must be checked and maintained at least once every six months. Check closing of door and operation of locking elements. Detailed information is available in maintenance manual. It is possible to sign a maintenance contract upon purchasing the door.

